



X	Tür abnehmen	min. 170 mm
X	Tür aufklappen	min. 700 mm
X	Filter entnehmen	min. 400 mm
Y	elektrischer Anschluss	min. 100 mm empf. 300 mm
Z	Anschlußkabel	min. 200 mm

ruck^{eu}
VENTILATOREN
ruck Ventilatoren
Max-Planck-Str. 5
D-97944 Boxberg

Protection Mark according to ISO16016
Created h.ragowski 05.04.2018
Drawn h.ragowski 05.04.2018
Released h.ragowski 08.05.2018
Disabled

1:20 A4 mm

General tolerances
DIN ISO 2768-c

ACCUK1200FOOJR

145767 00